



County of Los Angeles
Department of Public Works
Building & Safety /
Land Development Division

Plan Check No. _____
District No. _____

Title 26, Los Angeles County Code Fire Sprinkler System Correction Sheet

Building Address: _____

Owner: _____ Telephone No. _____

Architect Or Engineer: _____ Telephone No. _____

Applicant: _____ Telephone No. _____

Use of structure: _____ Valuation: _____

Remarks: _____

Your application for a permit together with plans and specifications has been examined, and you are advised that the issuance of a permit is withheld for the reasons hereinafter set forth. The approval of plans and specifications does not permit the violation of any section of the building code or other county ordinance or law.

1. Obtain approval from the Fire Prevention Bureau.
2. Obtain approval from the Structural Engineer of Record for verifying the structural capabilities of the super structure to support fire sprinkler piping full of water.
This approval shall be in the form of stamp indicating review and approval of the fire sprinkler system drawings, and signature by the Engineer of Record on fire sprinkler system drawings. Engineer shall certify the location of hangers, type of hangers, and method of connection to the supporting structure. Only statement or design criteria indicating that the uniformly distributed load of 1 or 2 lbs. per sq. ft. for sprinklers is included in the design of structure will not be acceptable.
Submit details of hanger connections showing the number, size and location of fasteners for pipes 4" and larger in size.
3. In case of sprinkler system suspended from the wood or steel trusses, wood or Joists obtain approval from the designer and fabricator of trusses or joists verifying the structural capabilities. Submit details of connections and local reinforcement of members required, if any, for connections to trusses and/or joists.
4. Note on Plan Sheet.
 - A. When serving more than 100 sprinklers, automatic sprinkler systems shall be supervised by an approved central, proprietary or remote station service or a local alarm which will give an audible signal at a constantly attended location. Sec. 3803
 - B. If emergency warning systems are required they shall activate a means of warning the hearing impaired. Flashing visual warning shall have a frequency of not more than 60 flashes per minute. Sec. 2-7204

